

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

Jim Doyle, Governor Mary P. Burke, Secretary

October 18, 2005

XERXES CORPORATION MIKE SLOAN 21518 262ND ST. DELHI IA 5223 XERXES CORPORATION MIKE SLOAN 7901 XERXES AVE SOUTH MINNEAPOLIS MN 55431

Re: Description: SEWAGE TANKS, FIBERGLASS

Manufacturer: XERXES CORPORATION
Product Name: HOLDING OR PUMP

Model Number(s): 600 gal.

(7' MAX. DEPTH OF BURY)

Product File No: 20050698

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2010.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This product must be installed in accordance with the manufacturer's printed instructions, the plan approval and s. Comm 83.15 (4), Wis. Admin. Code. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval and code requirements will take precedence.
- The side openings and lower end opening on this product may only be used when this product is installed as a holding tank.
- The gallon capacity per inch of the Xerxes Corp., 600 gallon tank is shown below as height from tank bottom / gallons capacity. (i.e. 11/103 = 11 inch liquid level equals 103 gallons in tank) 4/24, 5/33, 6/43, 7/54, 8/65, 9/77, 10/90, 11/103, 12/117, 13/131, 14/145, 15/160, 16/175, 17/191, 18/207, 19/223, 20/239, 21/255, 22/271, 23/287, 24/304, 25/320, 26/337, 27/353, 28/369, 29/385, 30/401, 31/417, 32/432, 33/447, 34/462, 35/476, 36/490, 37/504, 38/517, 39/529, 40/541, 41/552, 42/563, 43/572, 44/581, 45/588, 46/595 and 47/600.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

SBD-10564-E (N.10/97) File Ref: 05069801.DOC

XERXES CORPORATION Page 2 October 18, 2005

Sincerely,

Michael J. Beckwith, CIPE Plumbing Product Reviewer phone: 608-266-6742

fax: 608-267-9566

e-mail: mike.beckwith@wi.gov